

Business Name:	Date:
Address:	Phone #
Representative:	Phone #
Emergency Contact:	Phone #

Occupancy Type (circle): A B E F H I M R S U	Knox Box (If required): Yes No Location:	Knox FDC Caps (If required): Yes No
--	---	--

Status: No Issues Noted Unsatisfactory → Re-inspection Date: _____

Based Upon the 2012 International Fire Code

General	Code Ref.	Y	N	N A	Housekeeping	Code Ref.	Y	N	N A
Address visible from street.	505.1	✓			Areas are clean and free of waste	304.1	✓		
Hydrant/FDC free of obstructions	507.5.5	✓			Oily rags in approved containers	304.3.1, 305.2	✓		
Key Box Accessible, <i>Keys Checked</i>	506.1, 506.2	✓			Proper clearance to ignition sources	305.1, 315.3	✓		
Fire Access Roads Clear	503.4	✓			Fueled Equipment is Stored Properly	313, 314.4,	✓		
Electrical	Code Ref.	Y	N		Mechanical	Code Ref.	Y	N	
Electrical Outlet Boxes Cover Plates	605.6 604.6				Waste & Combustibles 5 ft. From Bldg.	315.3.1, 304.3.3	✓		
Electrical Panel is Accessible (30" W x 36" D x 78" H)	605.3 604.3				Equipment/Mechanical Room Free of Combustibles	315.3.3	✓		
Extension Cords Used for Temporary Portable Equipment Only (90 days max)	605.5 604.5, 604.9				Gas Meter & Piping Protected From Impact and Damage As Necessary	603.9	✓		
Emergency Lighting	Code Ref.	Y	N		Propane	Code Ref.	Y	N	
Egress Illumination is Functioning	1006.1 1008.1				Containers Protected From Traffic	6107.4	✓		
Egress Emergency Power functions.	1006.3 1008.3.5				No Smoking Signs Are Posted	6107.2			
Exits	Code Ref.	Y	N		Fire Sprinklers	Code Ref.	Y	N	
Exit Openable Without Key, Special Knowledge or Effort	1008.1.9 1010.1.9, 1008.1.9.3 1010.1.9.6				Sprinkler System Inspected/Tagged Records Available Upon Request	901.6.2 901.6.3			
Means of Egress Free of Obstruction	1003.6, 1030.3				Storage 18 inches Below Sprinklers	315.3.1	✓		
Exit Signs at Required Exits	1011.1 1013.1				Sprinkler System On & Monitored	903.4.1	✓		
Exit Signs Properly Illuminated	1011.3 1013.3				Stock of Spare Sprinklers	NFPA 13, 6.2.9	✓		
Unlatches With One Operation	1008.1.9.5 1010.1.9,6				FDC Accessible & Protective Caps	912	✓		
Fire Extinguishers	Code Ref.	Y	N		Kitchen Hoods	Code Ref.	Y	N	
Inspection & Service is Current	906.2	✓			Suppression System Inspected and Tagged	901.4.1	✓		
Fire Alarm Systems	Code Ref.	Y	N		Fire Doors	Code Ref.	Y	N	
Alarm System, Inspected & Tagged	907.8.5	✓			Fire Doors, Proper Operation	703.2, 1008 703.2, 1010			
Flammable Liquids	Code Ref.	Y	N		Storage	Code Ref.	Y	N	
Under 10 Gallons, Approved Container	5704.3.4.4	✓			Compressed Gas Cylinders Secured	5303.5.3	✓		
10 Gallons or More - Liquid Storage Cabinet (Maintenance/Operation Use)	5704.3.4.4	✓			Storage over 12 ft. Note and report to Fire Marshal	Chapters 2 & 32			

Chapter 2 - High Piles Storage & 32

Certificate Of Fire Clearance Granted. In Compliance? Yes No

(The granting of this clearance only implies that a reasonable degree of fire safety exists at the time of inspection. If any hazards, conditions or violations of the code are missed in this inspection, it does not imply acceptance or approval of such conditions and/or violations).

Fire Department Signature: _____
Print Name: _____

Recipient Signature: _____
Print Name: _____

Forwarded to the Fire Marshal: ____ / ____ / ____

By: _____

Shift: _____