



23 West 1900 North  
Hamburg, Utah 81111  
(801) 782-3580  
Fax (801) 782-3582

**Board of Trustees**  
Soaring Eagle  
Bob White  
Wyatt Yerp  
John Dillinger  
Fred Flintstone  
Barney Rubble  
John Wayne

December 4, 2014  
Elmer Fudd  
Bob's Hardware  
955 N 2000 W  
Hamburg, UT 81111

Re: Fire Safety Inspection

Dear Elmer:

Thank you for allowing us to use your facility as part of our training exercise. Everything about your facility; the location, the minor violations, your friendly staff and more, made it the perfect venue for this portion of our exercise. As part of this exercise we have completed a fire safety inspection of your facility. The following are the violations found:

- No address on building. IFC 505.1
  - No key box on building IFC 506.1 (Recommendation only)
  - Emergency exit sign illumination IFC 1011.5.3
  - Fire extinguisher obstructed IFC 509.2, 906.6
    - Extinguisher at front door
    - Extinguisher North central area
    - Receiving area
    - Upstairs office (hat)
  - Extension cord on floor and under trough IFC 605.5
  - Extension cord in place of permanent wiring IFC 605.5
    - In fire arm area
    - Hat shaping area
    - Receiving area, (four typical)
    - Break room
    - Under stair storage
  - Power Tap (light strip or power strip) in an extension cord IFC 605.4.2
    - Hat shaping area
    - Receiving area (two typical)
    - Break room
    - Jewelry area
    - Under stair storage
  - Emergency lighting pointed other than at the floor IFC 1006.2
    - Northwest door
    - Front doors
  - North east door obscured IFC 1008.1 (Bandanas)
- 
-

- Receiving area general housekeeping IFC 315.2
- Fire Extinguisher too high in upstairs office IFC 906.9.1
- Emergency lighting non-functioning at front doors IFC1006.2
- Accessible clearance around electrical panels IFC 605.3 (nothing in red paint)
- Accessible clearance around fire sprinkler valve assembly IFC 509.2 (nothing in red paint)
- Painted fire sprinklers NFPA 13
  - Over break room
  - North center area

Thanks again for all of your help. I will schedule a follow up inspection with you to help with the safety of your building.

Sincerely,

Captain America  
Fire Marshal

cc: File

---

---